

# Spokane County, WA – Industrial Pretreatment Program

---

## Local Limits:

Spokane County has established Local Limits in its Pretreatment Ordinance 8.03A.0204:

A. The following limits are established to protect against pass through and interference, expressed as Maximum Allowable Discharge Limits. No Significant Industrial User may discharge wastewater into any sewer which conveys wastewater to the Spokane County Regional Water Reclamation Facility in excess of the following concentrations:

Arsenic: 0.12 mg/L.

Benzene: <0.5 mg/L.

Cadmium: 0.07 mg/L.

Total Chromium: <5.0 mg/L.

Copper: 0.74 mg/L.

Cyanide: 1.01 mg/L.

Fats, oils and, grease: See [SPOKANE COUNTY CODE 8.03A.0201 B 19](#).

Lead: 0.32 mg/L.

Mercury: 0.012 mg/L.

Molybdenum: 0.66 mg/L.

Nickel: 1.74 mg/L.

Selenium: 0.40 mg/L.

Silver: 0.46 mg/L.

Zinc: 2.59 mg/L.

The pH limit set in [SPOKANE COUNTY CODE 8.03A.0201 B\(2\)](#) may also be enforced as a Local Limit.

The above limits apply at the point where the wastewater is discharged to the POTW (end of pipe).

B. Users that discharge wastewater into any sewer which conveys wastewater to the City of Spokane Riverside Park Water Reclamation Facility must comply with the limits set forth in Spokane Municipal Code 13.03A.0204.